



CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality,
hereby attests that the product(s):

STEEL STRAND, UNCOATED SEVEN WIRE
(Details as per the attached Scope of Certification)

manufactured by:

WUXI JINYANG METAL PRODUCTS LTD. CO. (CHINA)
Yangjian Town, Wuxi, Jiangsu, China

have been assessed in accordance with DCLD Document Ref. No. RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

ASTM A 416 / A 416M - 10

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark to the above-mentioned product(s).

ENGR. HAWA-ABDULLA BASTAKI
Director, Dubai Central Laboratory Department
Dubai Municipality

Certificate No: CL08020043
Valid Until: 28 April 2012

Current Issue Date: 29 April 2011
Original Issue Date: 29 April 2008



CB-003

The attached Scope of Certification bearing the same Certificate No. forms an integral part of this certificate.
This certificate is subject to the Terms and Conditions of the Product Certification System

**DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL08020043**

Certificate Issued To: Wuxi Jinyang Metal Products (China)
Yangjian Town, Wuxi, Jiangsu, China

Applicable Standard Specification: ASTM A 416/A 416 M - 10 Specification for
Steel Strand, Uncoated Seven Wire for
Prestressed Concrete

Applicable Specific Rules: RD-DP21-2131 (IC) "Specific Rules for
Certification of Steel Strand, Uncoated Seven
Wire for Prestressed Concrete (as per ASTM
A 416/A 416 M - 10) Through Factory
Assessment".

S/N	Product Description	Nominal Diameter (mm)	Product Details
1	Steel Strand, Un-Coated Seven-Wire for Prestressed Concrete	9.53	Seven-Wire Low Relaxation Steel Strand No. 9, Grade 1860[270] with Nominal Diameter 9.53mm, minimum Breaking Strength of 102.3 kN.
2	Steel Strand, Un-Coated Seven-Wire for Prestressed Concrete	12.70	Seven-Wire Low Relaxation Steel Strand No. 13, Grade 1860[270] with Nominal Diameter 12.70mm, minimum Breaking Strength of 183.7 kN.
3	Steel Strand, Un-Coated Seven-Wire for Prestressed Concrete	15.24	Seven-Wire Low Relaxation Steel Strand No. 15, Grade 1860[270] with Nominal Diameter 15.24mm, minimum Breaking Strength of 260.7 kN.

NOTE: 1. This document forms part of the Certificate of Product Conformity bearing the same certificate number.
2. The above certified products shall bear the DCL Conformity Mark either on the tag or in packaging.

Original Issue Date : April 29, 2008
Current Issued Date : April 29, 2011
Valid Until : April 28, 2012



ENGR. AMIN AHMED MOHAMMED AMIN
Head of Inspection and Certification Section
Dubai Central Laboratory Department

Handwritten initials