



CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality,
hereby attests that the product(s):

MINERAL FIBER BLOCK AND BOARD THERMAL INSULATION

(Details as per the attached Scope of Certification)

manufactured by:

FUJAIRAH ROCKWOOL FACTORY

P.O. Box: 211 Fujairah, U.A.E.

have been assessed in accordance with DCLD Document Ref. No. RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

ASTM C 612 - 10

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark to the above-mentioned product(s).

ENGR. HAWA ABDULLA BASTAKI
Director, Dubai Central Laboratory Department
Dubai Municipality

Certificate No: CL06020019
Valid Until: 11 October 2012

Current Issue Date: 12 October 2011
Original Issue Date: 12 October 2006



CB-003



The attached Scope of Certification bearing the same Certificate No. forms an integral part of this certificate.
This certificate is subject to the Terms and Conditions of the Product Certification System

**DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL06020019**

Certificate Issued To: FUJAIRAH ROCKWOOL FACTORY
P.O. Box: 211 Fujairah, U.A.E.

Applicable Standard Specification: ASTM C 612-10 Standard Specification for Fiber Block and Board Thermal Insulation

Applicable Specific Rules: RD-DP21-2108 (IC) "Specific Rules for Certification of Mineral Fiber Block and Board Thermal Insulation (ASTM C 612-10) Through Factory Assessment".

S/N	Product Description	Product Brand	Product Details
1	Mineral Rockwool Semi-Rigid Board/Slab Thermal Insulation	Fujairah Rockwool	Type IB and Type II without facing k-value: 0.039 W/(m•K) Density range (for design purpose), 40 - 128 kg/m ³ Nominal Thickness, 30-120 mm Length: 1000 & 1200 mm Width: 500 & 600 mm Surface Burning Characteristic as per ASTM E 84 Flame Spread Index = 25 (max) Smoke Developed Index = 50 (max)

Note 1: Maximum k-value measured at 35°C temperature and 60% relative humidity condition

Note2: This document forms part of the Certificate of Product Conformity bearing the same certificate number.

Note3: The above products shall bear the DCL Conformity Mark (applied on each product or on the packaging).

Original Issue Date : October 12, 2006

Current Issue Date : October 12, 2011

Valid Until : October 11, 2012

ENGR. AMIN AHMED MOHAMMED AMIN
Head of Inspection and Certification Section
Dubai Central Laboratory Department