



## CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality,  
hereby attests that the product(s):

### MINERAL FIBER BOARD THERMAL INSULATION BOARD

(Details as per the attached Scope of Certification)

manufactured by:

**CSR (GUANGZHOU) BUILDING MATERIALS C. LTD.**  
Fuliyonglong Square No. 76, Huangpu Rd. Tianghe District, Guanzhou, China

have been assessed in accordance with DCLD Document Ref. No. RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

**ASTM C 612 - 10**

Accordingly, DCLD hereby authorizes the above manufacturer  
to affix the DCL Product Conformity Mark to the above-mentioned product(s).

**ENGR. HAWA ABDULLA BASTAKI**  
Director, Dubai Central Laboratory Department  
Dubai Municipality

Certificate No: CL11020145  
Valid Until: 26 April 2012

Current Issue Date: 27 April 2011  
Original Issue Date: 27 April 2011

The attached Scope of Certification bearing the same Certificate No. forms an integral part of this certificate.  
This certificate is subject to the Terms and Conditions of the Product Certification System



**DUBAI CENTRAL LABORATORY DEPARTMENT  
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION  
FOR CERTIFICATE NO. CL11020145**

**Certificate Issued To:** CSR (GUANGZHOU) BUILDING MATERIALS COMPANY, LTD.  
Fuliyinglong Square No. 76, Huangpu Rd. Tianghe District Guangzhou, China

**Applicable Standard Specification:** ASTM C 612-10 Standard Specification for Fiber Block and Board Thermal Insulation

**Applicable Specific Rules:** RD-DP21-2108 (IC) "Specific Rules for Certification of Mineral Fiber Block and Board Thermal Insulation (ASTM C 612-10) Through Factory Assessment".

S/N	Product Description	Product Brand	Product Details
1	Mineral Rock Wool Thermal Insulation Board with aluminum foil facing	FIBERTEX R 60	Type IA and Type IB k-value: 0.037 W/(m·K) @ 35°C and 60% RH Density = 60 kg/m <sup>3</sup> Nominal Thickness, 30-150 mm Length: 1200 mm Width: 600 mm Surface Burning Characteristic as per ASTM E 84 Flame Spread = 0 Smoke Developed Index = 50
2	Mineral Rock Wool Thermal Insulation Board with aluminum foil facing	FIBERTEX R 80	Type IA and Type IB k-value: 0.036 W/(m·K) @ 35°C and 60% RH Density = 80 kg/m <sup>3</sup> Nominal Thickness, 30-150 mm Length: 1200 mm Width: 600 mm Surface Burning Characteristic as per ASTM E 84 Flame Spread Index = 0 Smoke Developed Index = 50

Note 1: The above products shall bear the DCL Conformity Mark (applied on each product or on the packaging)

Note2: This document forms part of the Certificate of Product Conformity bearing the same certificate number.

Original Issue Date : 27 April 2011  
Current Issue Date : 27 April 2011  
Valid Until : 26 April 2012



ENGR. AMIN AHMED MOHAMMED AMIN  
Head of Inspection and Certification Section  
Dubai Central Laboratory Department